



Procurement Department Bid Section
225 North Pearl Street
Jacksonville, Florida 32202

June 10, 2024

ADDENDUM NUMBER: Two (2)

TITLE: Mandarin WRF High Mast Poles Upgrades - 1411706846

RESPONSE DUE DATE: June 17, 2024

TIME OF RECEIPT: 12:00 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. A Second Optional Site visit will be held on Wednesday, June 12, 2024, 12:00 PM at 10828 Hampton Rd, Jacksonville FL, 32257

2. Question: The FDOT FY 2024-25 Standard Plans High Mast Lighting 715-010 are for 80', 100' and 120' poles. Please provide the FDOT Standard Plans for 70' poles. The existing pole foundations are insufficient for 80' poles.

Answer: There is no available index for 70' poles, Please use the guidelines in FDOT standards attached.

3. Question: What are the existing poles model number? Specifications sheet?

Answer: Existing poles are [70' GRTS POLE H4457], designed for [Holophane HMS-LD15-5-HMDTC10HP-L1] lowering device. Specifications sheets not available in record.

4. The following changes have been made to Appendix A – Technical Specifications:

1. Line number 8 removed from the scope, as the contractor will not install a new foundation:
- ~~2. 8. Contractor to ensure foundation design stamped by registered civil professional engineer.~~
3. Line number 14 added to the scope.
4. 14. Contractor is responsible for ensuring the existing foundations will fit the new poles Base plate design and spaces between Anchor Bolts

Please see updated Appendix A- Technical Specifications attached.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE RESPONSE FORM