



Procurement Department Bid Section  
225 North Pearl Street  
Jacksonville, Florida 32202

July 3, 2024

ADDENDUM NUMBER: Two (2)

TITLE: Facilities Roof Replacement for 210 Hollybrook Avenue Master Lift Station - 1411772447

RESPONSE DUE DATE: July 12, 2024

TIME OF RECEIPT: 1:00 PM EST

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

1. **The Due Date has been changed from July 9, 2024 to July 12, 2024 at 1PM EST.**
2. Question- Regarding the mechanical unit that is on the lower roof. Is anything happening with that unit? I.e. replace, raise curb, ect.?

Answer- The unit is only 5-6 years old and will not be replaced, new ply sheets to be installed under unit and flash or liquid flash required areas.

3. Question- Is JEA or the supplier responsible for the providing the VCO on onsite?

Answer- JEA to provide preferred VCO to monitor construction for 10 days, any additional days will be deducted from contract amount.

**ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE RESPONSE FORM**