



Building Community®

Procurement Department Bid Office
225 N. Pearl St.
Jacksonville, Florida 32202

October 24, 2024

ADDENDUM NUMBER: One (1)

TITLE: Kennedy TP7SU Transformer Replacement

JEA SOLICITATION NUMBER: 1411861046

RESPONSE DUE DATE: October 29, 2024

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. Revision: Scope of Work

All cranes, scaffolding, and miscellaneous lift equipment and services required for relocating, unloading, assembling, or testing electrical equipment shall be supplied by the contractor.

Crane services and transformer testing for the Kennedy TP7SU will be provided by JEA. The contractor is responsible for assembling the transformer and terminating the cables as shown in the cable schedule. Additionally, the contractor must pick up the materials from the JEA storeroom in Jacksonville to the job site and provide construction support while JEA crews test and commission the new transformer.

2. Clarification:

The BOM and Photos are provided as requested. Ground cable #3/0 shall be furnished by the contractor (See item ID 104 in the BOM).

3. Clarification: The contractor shall mobilize crews in November and pull the underground (UG) cables in advance to ensure readiness for the scheduled outage.

The contractor transport the UG cables and associated items from JEA storeroom to Job site, and relocate fire suppression system to ensure readiness for the scheduled outage. The existing UG cables will be removed, and new UG cables will be pulled after the outage begins.

4. Questions: I have quote for Operator platform and lead time is 45 days. May this impact to finish on December 2024?

This is acceptable. We can receive the operator platform in January if the lead time is 45 days.

5. Questions: May you confirm that crane will be by JEA?

JEA will provide crane service and transformer testing.

6. JEA adds "1411861046 Appendix C - REVISED Project Scope"
7. JEA adds "1411861046 Appendix E - KP2024-BOM"
8. JEA adds "1411861046 Appendix F - Kennedy TP7SU Photo"
9. JEA adds "1411861046 Appendix G - Kennedy Transformer TP7SU Cable Schedule"
10. JEA adds "1411861046 Mandatory Pre-bid Meeting Attendees List"