

TECHNICAL SPECIFICATION

FOR

NGS FUEL DOME "A"
STAKER BOOM
CHUTE

Equipment / System Specification

A. Process Parameters / Operating Conditions

- The new chutes to be fabricated from ½" thick through hardened plate with 3/8" A36 steel flanges.
- The deflectors to be fabricated from through hardened steel plates in lieu of ceramic plates like the original design.

ATTACHMENTS

