



Procurement Department Bid Office
225 N. Pearl St.
Jacksonville, Florida 32202

February 14, 2025

ADDENDUM NUMBER: One (1)

TITLE: B53 UAT Replacement

JEA SOLICITATION NUMBER: 1411928246

RESPONSE DUE DATE: February 21, 2025

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. JEA adds “1411928246 Addendum 1.”
2. Phase 1 working days will be March 6, 2025 – March 13, 2025.
3. The IPB must be closed to the elements at the end of each shift to keep wildlife and debris out.
4. **QUESTION:** Does the bushing box stay, or does it need to be removed?

ANSWER: The bushing box can be removed during the outage long enough to remove the bushings if they need to be removed and it’s the only way they can come out.

5. **QUESTION:** Will the transformer need to be removed and put back in?

ANSWER: Yes.