



Procurement Department Bid Office  
225 N. Pearl St.  
Jacksonville, Florida 32202

March 11, 2025

ADDENDUM NUMBER: Two (2)

TITLE: Fiber Optic Ground Wire (OPGW) for Fulton Cut Replacement

JEA SOLICITATION NUMBER: 1411937846

RESPONSE DUE DATE: March 27, 2025

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

1. JEA adds “1411937846 Addendum 2.”
2. JEA to change language in technical specification to specify a left-hand lay for the outside layer of the cable. This change occurs in 3.1.1. as follows:

The direction of lay of the outside layer of aluminum wire shall be left-hand. The direction of lay of the aluminum and core wires shall be reversed in successive layers.

3. JEA adds “1411937846 Appendix A – Technical Specifications - Revised to Include Addendum 2.”