



Building Community®

Procurement Department Bid Section
225 North Pearl Street
Jacksonville, Florida 32202

March 24, 2025

ADDENDUM NUMBER: Five (5)

TITLE: Storm Event Shower Trailer Rentals - 1411941046

RESPONSE DUE DATE: April 1, 2025

TIME OF RECEIPT: 2:00 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

- 1. Question** – Appendix A, Safety and Emergency Requirements -Trailers do not come with fire extinguishers. We can buy separately and place inside the trailer cabins but it would not be mounted to the wall. Will the City approve?

Answer – JEA intends to require the following Fire Marshall requirements: at least one (1) 6lb fire extinguisher, type ABC, mounted inside, and located near either the entrance or exit door (only needs to be one per trailer).

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE RESPONSE FORM