



Procurement Department Bid Office  
 225 N. Pearl St.  
 Jacksonville, Florida 32202

March 13, 2025

ADDENDUM NUMBER: One (1)

TITLE: Purchase of Resin for NGS Unit 1 Condensate Polishers

JEA SOLICITATION NUMBER: 1411948846

RESPONSE DUE DATE: March 14, 2025

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

- Question:** Can you confirm that what is listed in the specifications is what is being requested and that the products you want are Uniform Particle Size microporous resins?

**Answer:** Yes, we are requesting Uniform Particle Size Macroreticular.

- Question:** It shows HPR8300 H or equivalent. This is a weak acid cation. Not a strong base anion. Do you need a SBA?

**Answer:** Yes, it needs to be strong base anion. Below is what we use in our polishers.

Polishers (4 beds total)														
u1	Cation Resin	Rohm Haas	SAM	Amberlite 200C H	H+	80	11.4	12	dum	490	6/1/2003 (R&H)	400 lbs/16 bags Total for all: 1600 lbs/64 bags	CHM-RN-005	49 lbs/cu ft
		LanXess	SAM	SP-112 (BH 200 H+)	H+	80	11.4	12	dum					
u1	Anion Resin	Rohm Haas	SEM	Ambersep 900 OH	DH+	40	5.7	6	dum	490	6/1/2003 (R&H)	400 lbs/16 bags Total for all: 1600 lbs/64 bags	CHM-RN-004	49 lbs/cu ft
		LanXess	SEM	MP-500 (BH 900 OH)	DH+	40	5.7	6	dum					