



Procurement Department Bid Section
225 North Pearl Street
Jacksonville, Florida 32202

March 19, 2025

ADDENDUM NUMBER: Two (2)

TITLE: JEA Royal Lakes Water Treatment Plant (WTP) Office Storage Upgrade – 1411949848

RESPONSE DUE DATE: ~~March 28, 2025~~, April 2, 2025

TIME OF RECEIPT: 12:00 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Question:** Please confirm new countertop with open shelving below is to be installed in the same footprint as the existing to be demolished?

Answer: New countertop with open shelving below will be in the same footprint as existing.

2. **Question:** Please confirm if upper cabinets are desired once the existing is demolished?

Answer: In lieu of upper cabinets, install open shelving. Shelving to be 12” wide, the length of the countertop, with 4 shelves. Stringer & bracket style shelving is acceptable, color TBD but from manufacturer’s standard colors.

3. **Question:** What are the electrical and data requirements for the furniture installation?

Answer: The furniture design is not yet complete. Include a \$2500 line item for “Furniture Electrical & Data” in your bid.

4. **Question:** Is the exterior door frame replacement to be steel or aluminum?

Answer: Both the doors and the frame are to be steel. Doors and frame will be painted, color TBD.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE RESPONSE FORM