



Building Community

DUMPSTER DRAIN GUIDANCE

JEA's Industrial Pretreatment Team can approve discharge to the sewer system from dumpsters *only if* the drainage cannot be routed to a treatment swale.



FAQs



WHEN A TREATMENT SWALE IS NOT POSSIBLE

The area must be covered and sloped/elevated to prevent storm water intrusion to the drain. The drain wastewater must then be routed through a properly sized Grease Separation Device (GSD) that meets JEA requirements.



DRAINAGE FOR NEW BUILDS

New construction projects should go through SAGES for assistance and approval. To access SAGES, go to www.sagesgov.com.



WHEN A TREATMENT SWALE IS POSSIBLE

Treatment swales in this instance are under the jurisdiction of the City of Jacksonville (COJ). Reach out to COJ for further guidance at stormwater@coj.net.



DRAINAGE FOR EXISTING BUILDS

Existing builds should reach out to JEA's Industrial Pretreatment team at ip@jea.com and provide the following: plans, sizing calculations, Grease Separation Device (GSD) shop drawings, and Device certifications (applicable if a Hydromechanical Grease Interceptor (HGI) is proposed).

HAVE MORE QUESTIONS?

Visit us at www.jea.com/industrialpretreatment or contact us using the information below.



(904) 665-5326



ip@jea.com