

## January 2024

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

8001 Baymeadows Way

Jacksonville, FL 32256

Duval County

Monday, January 8, 2023 @ 12:22pm

Estimated gallons released: 3000

Action Taken: Vacuum truck used to clear blockage from gravity line to stop overflow.

Due to location of spill, no recovery is able to be made. Sampling of creek will begin on 1/9/2024.

Preliminary Cause: Equipment Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

8001 Baymeadows Way

Jacksonville, FL 32256

Duval County

Monday, January 22, 2023 @ 3:06pm

Estimated gallons released: 200

Action Taken: Blockage removed to stop overflow.

Preliminary Cause: Blockage

1715 Kings Rd

Jacksonville, FL 32204

Duval County

Tuesday, January 23, 2024 @ 11:30 AM

Estimated gallons released: 100

Action Taken: Removed grease blockage, washed down and recovered all sewer/wash water from storm drain

Preliminary Cause: Grease

7380 Philips Highway

Jacksonville, FL 32256

Duval County

Tuesday, January 30, 2024 @ 11:26 AM

Estimated gallons released: 900

Action Taken: Force main was repaired. Rain/ditch water, sewer, and wash water were recovered. Affected area was washed down.

Preliminary Cause: 3rd Party

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

3609 Colony Cove Trail West - 1/5/2024 @ 5:00 pm - 5 gallons

6353 Lake Plantation Drive - 1/28/2024 @ 8:55 pm - 50 gallons

#### Other Events Reported To The State Watch Office

Alumni Dr and UNF Dr

Jacksonville, FL 32224

Duval County

Monday, January 8, 2024 @ 11:39am

Estimated gallons spilled: 10,000

Action Taken: Valves closed to stop overflow. Contractor to repair pipe.

Preliminary Cause: Contractor Error

#### February 2024

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

12222 Old Saint Augustine Rd

Jacksonville, FL 32258

Duval County

Thursday, February 22, 2024 @ 11:20 AM

Estimated Gallons: 1500

Action Taken: ARV was shut off and area was washed down. Large vac trucks recovered basin water and sewer out of 2 down stream storm water basins.

Preliminary Cause: ARV

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

3640 Las Vegas Rd

Jacksonville, FL 32257  
Duval County  
Friday, February 2, 2024 @ 10:29 AM  
Estimated gallons released: 200  
Action Taken: Small vactor maintained spill until crew arrived onsite. Large vactor assisted while leaking nipple/valve repaired to stop leak.  
Preliminary Cause: Equipment Failure

2426 Jerusalem St  
Jacksonville, FL 32207  
Duval County  
Friday, February 9, 2024 @ 12:00 PM  
Estimated gallons released: 300  
Action Taken: Vactor removed blockage from manhole. Full recovery of sewer made in storm drain and street was washed down.  
Preliminary Cause: Overflow

3338 Secret Isle Ln  
Jacksonville, FL 32225  
Duval County  
Monday, February 12, 2024 @ 9:13 AM  
Estimated gallons released: 100  
Action Taken: Blockage was cleared and overflow was stopped. Affected area was washed down and recovered sewer/wash water from storm drain basin.  
Preliminary Cause: NA

7233 Blanding Blvd  
Jacksonville, FL 32244  
Duval County  
Tuesday, February 13, 2024 @ 5:00 PM  
Estimated gallons released: 200  
Action Taken: Valve closed on ARV to stop release. All sewer recovered from ditch line.  
Preliminary Cause: Failed ARV

3585 Saint Johns Ave  
Jacksonville, FL 32205  
Duval County  
Monday, February 20, 2024 @ 12:45 PM  
Estimated gallons released: 50  
Action Taken: Vactor removed blockage from manhole. Full recovery of sewer made in storm drain and street was washed down.  
Preliminary Cause: Grease

801 East Union St

Jacksonville, FL 32206

Duval County

Wednesday, February 21, 2024 @ 9:00 AM

Estimated gallons released: 100

Action Taken: Large factor jetted line to unstop grease blockage. Washed down area and recovered all wash water/sewer from storm drain.

Preliminary Cause: Blockage

8835 Ricardo Ln

Jacksonville, FL 32216

Duval County

Thursday, February 22, 2024 @ 10:00 PM

Estimated gallons released: 50

Action Taken: Customer cleanout overflowing into yard. JEA system was unblocked. The affected area was washed down and vacuumed up.

Preliminary Cause: Debris

5046 Windflower Ct

Jacksonville, FL 32218

Duval County

Monday, February 26, 2024 @ 08:44 AM

Estimated gallons released: 200

Action Taken: Vactor flushed out line to stop overflow. Crew came to remove contractor bag out of line. Full recovery of sewer made in storm drain and street was washed down.

Preliminary Cause: Blockage

12397 Huntley Ct

Jacksonville, FL 32224

Duval County

Monday, February 26, 2024 @ 8:23 PM

Estimated Gallons: 200

Action Taken: Blockage cleared, impacted area washed down and sewer recovered from storm drain.

Preliminary Cause: Grease

10339 Woodley Creek Blvd

Jacksonville, FL 32218

Duval County

Tuesday, February 27, 2024 @ 9:55 AM

Estimated gallons released: 100

Action Taken: Replaced pipe, vactor washed down street.

Preliminary Cause: Pipe Failure Force Main

14797 Philips Highway

Jacksonville, FL 32256

Duval County

Wednesday, February 28, 2024 @ 12:30 PM

Estimated gallons released: 500

Action Taken: Area washed down and all wash water/sewer recovered from ground and storm drain.

Preliminary Cause: Operator Error

6501 Arlington Expy

Jacksonville, FL 32211

Duval County

Thursday, February 29, 2024 @ 2:00 PM

Estimated gallons released: 50

Action Taken: Repaired pipe, vactor washed down parking lot and recovered sewer from storm drain.

Preliminary Cause: Contractor Error

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

2/2/2024 @ 3:48 PM - 1006 Glen Echo Road - 20 gallons

2/2/2024 @ 8:05 PM - 3353 Washburn Road - 10 gallons

2/6/2024 @ 7:15 PM - 8204 Free Avenue - 2 gallons

2/12/2024 @ 8:41 AM - 10656 Kennedy Ln - 1 gallon

2/19/2024 @ 7:45 PM - 660 Roberts Road - 10 gallons

#### Other Events Reported To The State Watch Office

None

#### March 2024

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

3632 Valencia Rd

Jacksonville, FL 32205

Duval County

Sunday, March 3, 2024 @ 12:00 PM  
Estimated Gallons: 500  
Action Taken: Blockage cleared and roadway washed down.  
Preliminary Cause: Grease

7673 Blanding Blvd  
Jacksonville, FL 32244  
Duval County  
Sunday, March 4, 2024 @ 1:18 PM  
Estimated Gallons: 5500  
Action Taken: Pipe repaired, standing sewer recovered and washed down. Applied hydrated lime.  
Preliminary Cause: Contractor Error

6262 Townsend Blvd  
Jacksonville, FL 32244  
Duval County  
Wednesday, March 6, 2024 @ 8:13 PM  
Estimated Gallons: 2300  
Action Taken: Blockage was cleared. Affected driveway washed down and recovered, affected grass applied with hydrated lime.  
Preliminary Cause: Gravity line blockage

14272 Pecan Park Rd  
Jacksonville, FL 32218  
Duval County  
Monday, March 11, 2024 @ 11:00 AM  
Estimated Gallons: 6000  
Action Taken: Pipe was repaired, sewer recovered out of pit and out of ditch. Area was washed down and remaining sewer/wash water recovered.  
Preliminary Cause: 3rd Party

3625 University Blvd S  
Jacksonville, FL 32216  
Duval County  
Monday, March 11, 2024 @ 4:00 PM  
Estimated Gallons: 200  
Action Taken: Line was unblocked. Road washed down and wash water vacuumed up.  
Preliminary Cause: Blockage

281 King St  
Jacksonville, FL 32204  
Duval County  
Wednesday, March 13, 2024 @ 11:06 AM

Estimated Gallons: 1,000

Action Taken: None. Unable to recover due to location of spill, sampling of McCoys Creek begins 3/14/2024.

Preliminary Cause: Unknown

7306 Strato Rd

Jacksonville, FL 32210

Duval County

Thursday, March 14, 2024 @ 1:29 PM

Estimated Gallons: 500

Action Taken: Recovered some sewer out of storm drain, sampling of Fishing Creek begins 3/15/2024.

Preliminary Cause: Gravity Line Blockage

Commonwealth Ave & Ellis Rd

Jacksonville, FL 32254

Duval County

Friday, March 22, 2024 @ 11:17 AM

Estimated gallons released: 3770

Action Taken: Dug up and replaced 10ft of sewer line. Washed down and recovered sewer in storm system.

Preliminary Cause: Pipe Failure

2426 Pine Island Ct

Jacksonville, FL 32224

Duval County

Tuesday, March 26, 2024 @ 10:12 PM

Estimated gallons released: 100

Action Taken: Repaired Step Pump. Unable to sample due to impacting Intracoastal Waterway.

Preliminary Cause: Equipment Failure

3220 Keniston Lane

Jacksonville, FL 32277

Duval County

Tuesday, March 26, 2024 @ 10:20 PM

Estimated gallons released: 27,000

Action Taken: Repaired pipe, vacuum trucks recovered sewer from pipe, washed down street, recovered sewer from storm drain. Sampling began 3/27/24.

Preliminary Cause: Construction Error

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

2133 Belinda Circle  
Jacksonville, FL 32216  
Duval County  
Friday, March 1, 2024 @ 6:45 AM  
Estimated gallons released: 500  
Action Taken: Wash down street and recover from storm drain.  
Preliminary Cause: Grease

12180 Nettlecreek Dr  
Jacksonville, FL 32225  
Duval County  
Monday, March 4, 2024 @ 3:30 PM  
Estimated gallons released: 100  
Action Taken: Cleared blockage, washed down area.  
Preliminary Cause: Blockage

2150 Park St  
Jacksonville, FL 32204  
Duval County  
Thursday, March 14, 2024 @ 3:10 PM  
Estimated gallons released: 50  
Action Taken: Wash down parking lot.  
Preliminary Cause: Pipe Failure

10210 Haley Rd  
Jacksonville, FL 32257  
Duval County  
Thursday, March 14, 2024 @ 4:01 PM  
Estimated gallons released: 600  
Action Taken: Wash down area in lift station.  
Preliminary Cause: Equipment Failure

Main St N and Cottage Ave  
Jacksonville, FL 32206  
Duval County  
Monday, March 18, 2024 @ 4:46 PM  
Estimated gallons released: 100  
Action Taken: Blockage removed by jetting. Roadway washed down and all sewer recovered.  
Preliminary Cause: Cave in

7703 Blanding Blvd  
Jacksonville, FL 32244

Duval County

Wednesday, March 27, 2024 @ 1:30 AM

Estimated gallons released: 50

Action Taken: Recovered sewer from customer's yard.

Preliminary Cause: Other

1280 West 30th St

Jacksonville, FL 32209

Duval County

Wednesday, March 27, 2024 @ 12:23 PM

Estimated gallons released: 50

Action Taken: Sewer lateral repaired and release was stopped. Sewer was recovered.

Area washed down and all wash water recovered.

Preliminary Cause: 3rd Party

2984 Snow Drop Ct

Jacksonville, FL 32209

Duval County

Thursday, March 28, 2024 @ 6:52 PM

Estimated gallons released: 100

Action Taken: Suction hoses used to recover sewer. Pipe replaced.

Preliminary Cause: Cave In

1234 Carthage Drive

Jacksonville, FL 32218

Duval County

Sunday, March 31, 2024 @ 11:05 AM

Estimated gallons released: 500

Action Taken: Recover sewer from storm drain.

Preliminary Cause: Equipment Failure

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

12568 Westberry Hideaway Lane - 3/15/2024 @ 2:00 PM - 25 gallons

11455 Beecher Circle East - 3/26/2024 @ 3:39 PM - 30 gallons

7942 Baymeadows Rd - 3/29/2024 @ 8:50 AM - 5 gallons

#### Other Events Reported To The State Watch Office

13172 Gran Bay Pkwy - 3/2/2024 @ 4:00 AM - 48 gallons

2221 Buckman St - 3/9/2024 @ 11:00 PM - 100,000 partially treated

## April 2024

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

7621 Centurion Pkwy  
Jacksonville, FL 32256

Duval County

Thursday, April 4 2024 @ 07:59 AM

Estimated gallons released: 10500

Action Taken: Vacuum trucks recovered sewer. Pump installed. Valve was removed and replaced with pipe. Lift station washed down and recovered. Sampling begins 4/5/2024.

Preliminary Cause: Equipment Failure

7318 Strato Road  
Jacksonville, FL 32210

Duval County

Thursday, April 16 2024 @ 10:08 AM

Estimated gallons released: 500

Action Taken: Blockage removed. Large vac truck recovered sewer from storm drain. Sampling begins 4/17/2024.

Preliminary Cause: Grease Blockage

155 East Peyton Parkway  
St. Johns, FL 32259

St Johns County

Friday, April 16, 2024 @ 9:20 AM

Estimated gallons released: 2100

Action Taken: Bypass pump replaced and standing sewer soaked into ground. Large vacuum truck washed down affected areas and recovered sewer/wash water.

Preliminary Cause: Equipment Failure

3613 Lane Ave South  
Jacksonville, FL 32210

Duval County

Thursday, April 18 2024 @ 3:28 PM

Estimated gallons released: 13500

Action Taken: Pipe replaced, Vacuum trucks recovered sewer. Impacted area washed down and flushed. Sampling begins 4/19/2024.

Preliminary Cause: Pipe Failure

8784 Perimeter Park Blvd  
Jacksonville, FL 32216  
Duval County  
Thursday, April 23 2024 @ 12:45 PM

Estimated gallons released: 55292

Action Taken: Vacuum trucks recovered sewer from impacted area and lift station. Pipe replaced. Impacted area washed down and recovered. Sampling begins 4/24/2024.

Preliminary Cause: Pipe Failure on Force Main

9737 Fort Caroline Rd  
Jacksonville, FL 32225  
Duval County  
Thursday, April 24 2024 @ 7:47 PM

Estimated gallons released: 10350

Action Taken: Vacuum truck arrived on-site to try and unblock main but unable to. A bypass pump was set up to divert flow from broken line. Construction crew onsite on 4/24/24 to dig up and repair/replace gravity line. Roadway washed down. Sampling of Miller Creek starting 4/24/24.

Preliminary Cause: Contractor Error

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

13983 Beach Blvd  
Jacksonville, FL 32250  
Duval County  
Sunday, April 7 2024 @ 11:45 AM

Estimated gallons released: 750

Action Taken: Pipe repaired. Impacted soil replaced and hydrated lime applied to area.

Preliminary Cause: Contractor Error

3210 Roosevelt Blvd  
Jacksonville, FL 32205  
Duval County  
Wednesday, April 10, 2024 @ 00:30 AM

Estimated gallons released: 100

Action Taken: Manhole was vacuumed out, area was washed down and recovered.

Preliminary Cause: Blockage

10800 Key Haven Blvd  
Jacksonville, FL 32218  
Duval County

Thursday, April 11, 2024 @ 5:45 PM

Estimated gallons released: 250

Action Taken: Pipe was valved off and leak was stopped, pipe to be repaired. Large vacuum truck recovered standing sewer and washed down area. Wash water also recovered. Hydrated lime applied to affected area.

Preliminary Cause: Contractor Error

903 Garrison Dr

Jacksonville, FL 32092

St. Johns County

Saturday, April 13, 2024 @ 9:16 AM

Estimated gallons released: 300

Action Taken: Pipe was repaired, and overflow was stopped. Sewer/wash water recovered out of surcharged storm water basin.

Preliminary Cause: Broken

1568 West 32nd St

Jacksonville, FL 32209

Duval County

Sunday, April 14, 2024 @ 6:41 PM

Estimated gallons released: 50

Action Taken: Blockage cleared, and overflow stopped. Street washed down and recovered. No storm drains or waterways impacted.

Preliminary Cause: Blockage

15493 Turkoman Cir

Jacksonville, FL 32218

Duval County

Monday, April 15, 2024 @ 8:00 PM

Estimated gallons released: 100

Action Taken: Blockage was cleared, road and curb washed down and vacuumed up. Water was vacuumed out of storm drain as well.

Preliminary Cause: Blockage

10962 Bonnelly Dr

Jacksonville, FL 32218

Duval County

Thursday, April 18, 2024 @ 1:18 PM

Estimated gallons released: 600

Action Taken: Vacuum truck pulled two loads out of storm drain for full recovery.

Preliminary Cause: Blockage

5100 Firestone Rd

Jacksonville, FL 32210

Duval County

Monday, April 22, 2024 @ 2:49 PM

Estimated gallons released: 200

Action Taken: Line in lift station has debris in it and was cleared. Crew called out and another pipe going to lift station had accumulated grease and was also cleared.

Preliminary Cause: Blockage

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

11232 Scott Mill Rd - 4/1/24 @ 5:00 PM - 10 gallons

8024 Southside Blvd - 4/2/24 @ 9:58 AM - 25 gallons

3580 State Road 13 North - 4/8/24 @ 5:00 PM - 5 gallons

2851 Armsdale Rd - 4/16/24 @ 12:34 PM - 5 gallons

6 San Diego Rd - 4/25/24 @ 4:20 PM - 5 gallons

3628 Ardisia Rd N - 4/28/24 @ 9:00 AM - 10 gallons

#### Other Events Reported To The State Watch Office

636 Kingsley Ave

Orange Park, FL 32073

Clay County

Thursday, April 25, 2024 @ 4:30 AM

Estimated gallons released: 17

Action Taken: Boom placed in creek downstream of spill site and under storm drain to collect any oil that may drain out. Hulls is contracted to clean up waste oil from roadway. Pole, lines and transformer will be replaced by JEA/third party.

Preliminary Cause: Third Party Damage

#### May 2024

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

10386 Agave Road

Jacksonville, FL 32246

Duval County

Thursday, May 2, 2024 @ 11:20 AM

Estimated gallons released: 500

Action Taken: Replaced clay pipe with PVC. Recovered sewer from creek. Sampling began 5/3/2024.

Preliminary Cause: Cave In

Panther Creek Parkway and Chaffee Road S

Jacksonville, FL 32221

Duval County

Tuesday, May 21, 2024 @ 9:00 AM

Estimated gallons released: 13,200

Action taken: Pipe replaced. Recovered sewer from work pit and overflow structure.

Hydrated lime placed in grassy area. No waterways impacted.

Preliminary Cause: Third Party

14950 Inspire Way

St. Augustine, FL 32084

St. Johns County

Friday, May 24, 2024 @ 9:27 AM

Estimated gallons released: 33,000 gal

Action Taken: Pipe Repaired. Recovered sewer from work pit and dammed area.

Preliminary Cause: Contractor Error

3000 Dunn Ave

Jacksonville, FL 32218

Duval County

Monday, May 28, 2024 @ 9:42 AM

Estimated gallons released: 9,415

Action Taken: Bypass pump set up between manholes where break occurred. Area washed down with fresh water to minimize smell. No recovery from creek due to location in woods.

Preliminary Cause: Cave-in

10999 Chitwood Dr

Jacksonville, FL 32218

Duval County

Wednesday, May 29 @ 1:40 PM

Estimated gallons released: 6500

Action Taken: Vacuum trucks actively recovering sewer until lift stations/valves could be shut off. Pipe repaired and wastewater/pond water recovered from storm drain connected to pond. SSO sign placed at weir. Sampling of pond to begin 5/30/24.

Preliminary Cause: Broken pipe

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

None

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

7023 103rd St - 5/22/2024 @ 8:30 AM - 25 gallons

#### Other Events Reported To The State Watch Office

1840 Cedar Bay Rd - 5/21/2024 @ 2:00 PM - 27,000 gallons partially treated

#### June 2024

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

7133 Southside Blvd  
Jacksonville, FL 32256

Duval County

Wednesday, June 12, 2024 @ 11:49 AM

Estimated gallons released: 1000

Action Taken: A bypass pump was set up to stop overflow. Contractor hired to drill in a new 36" force main under culvert to tie into existing 24" force main on either side of culvert and abandon leaking 24" force main under culvert.

Preliminary Cause: Pipe Failure

7111 Davis Creek Rd  
Jacksonville, FL 32256

Duval County

Wednesday, June 26, 2024 @ 2:20 PM

Estimated gallons released: 6000

Action Taken: Area vacuumed up and lime applied.

Preliminary Cause: 3<sup>rd</sup> Party

4035 Plantation Oaks Blvd  
Orange Park, FL 32065

Clay County

Saturday, June 29, 2024 @ 8:00 AM

Estimated gallons released: 4000

Action Taken: Once fixed hard areas were washed down and vacuumed up and hydrated lime was applied to easement.

Preliminary Cause: Pipe Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

1240 Skye Dr W

Jacksonville, FL 32221

Duval County

Sunday, June 2, 2023 @ 7:41 PM

Estimated gallons released: 600

Action Taken: Large vacuum truck called in to unblock system. Area washed down and all wash water recovered. Full recovery made from storm drain/ditch.

Preliminary Cause: Blockage

13288 Pacemaker Dr

Jacksonville, FL 32225

Duval County

Thursday, June 13, 2024 @ 6:24 AM

Estimated gallons released: 400

Action Taken: Sewer soaked into ground. Remaining standing sewer vacuumed, washed down and recovered. Valve closed properly.

Preliminary Cause: 3rd Party

5004 Walcott Ave

Jacksonville, FL 32209

Duval County

Monday, June 17, 2024 @ 2:20 PM

Estimated gallons released: 200

Action Taken: Pipe was repaired by JEA and sewer recovered from ditch line.

Preliminary Cause: Third Party

8219 Shady Grove Ct

Jacksonville, FL 32256

Duval County

Monday, June 24, 2024 @ 9:55 AM

Estimated gallons released: 500

Action Taken: Blockage removed by vacuum truck. Area washed down. Hydrated lime

applied to customers backyard.  
Preliminary Cause: Manhole Failure

8231 Shady Grove Ct  
Jacksonville, FL 32256  
Duval County

Thursday, June 27, 2024 @ 10:18 AM

Estimated gallons released: 500

Action Taken: Overflow was stopped and sewer soaked into ground, hydrated lime applied to affected areas. Sewer in street was washed down and recovered. Bypass pump set up to prevent future overflow until line inspection can be done.

Preliminary Cause: Cave In

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

9274 Baymeadows Rd - 6/10/24 5:00 PM - 30 gallons

#### Other Events Reported To The State Watch Office

7530 Kinlock Dr S - 6/3/24 @ 8:51 AM - 530 gallons diesel spill occurred at a JEA facility.  
No land or waterway impact.

#### **July 2024**

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

15807 Bainebridge Dr  
Jacksonville, FL 32218  
Duval County

Sunday, July 21, 2024 @ 9:18 AM

Estimated gallons released: 5000

Action Taken: Valve was shut off to stop overflow. Pipe was repaired and area treated with hydrated lime. Retention ponds and creek will be sampled starting 7/22/24.

Preliminary Cause: Pipe Failure

1555 Millco Rd

Jacksonville, FL 32225  
Duval County  
Wednesday, July 24, 2024 @ 6:40 AM  
Estimated gallons released: 5500  
Action Taken: Sewer recovered, hydrated lime placed, and ARV was replaced.  
Preliminary Cause: Failed ARV

7765 Club Duclay Dr  
Jacksonville, FL 32244  
Duval County  
Friday, July 26, 2024 @ 12:30 PM  
Estimated gallons released: 3,240  
Action Taken: Vacuum truck recovered sewer from curblin. Heavy rain started upon arrival. No further recovery possible. Sampling of pond to start 7/26/24.  
Preliminary Cause: Third Party

7777 Normandy Blvd  
Jacksonville, FL 32221  
Duval County  
Friday, June 26, 2024 @ 4:15 PM  
Estimated gallons released: 1,000  
Action Taken: Valve removed to allow private lift station to discharge. Hydrated lime applied to affected area.  
Preliminary Cause: Broken

Amelia Concourse & N Hampton Club Way  
Fernandina Beach, FL 32034  
Nassau County  
Monday, July 29, 2024 @ 9:33 AM  
Estimated gallons released: 50,332  
Action Taken: Large vacuum trucks recovered sewer from ground until valves could be shut off to stop overflow. Saddle to ARV rotted off pipe and had to be replaced. Area washed down and several loads taken from impacted storm drain.  
Preliminary Cause: Broken ARV

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)  
All releases between 50-999 gallons are reported to local agencies.

1555 Millco Rd  
Jacksonville, FL 32225  
Duval County  
Monday, July 1, 2024 @ 3:30 PM  
Estimated gallons released: 300

Action Taken: Lime applied to impacted area.  
Preliminary Cause: Blockage

2790 Emily Lane  
Jacksonville, FL 32216  
Duval County

Friday, July 5, 2024 @ 1:20 PM  
Estimated gallons released: 100

Action Taken: Street washed down. Sewer recovered from storm drain  
Preliminary Cause: Blockage

4492 Woodley Creek Rd  
Jacksonville, FL 32218  
Duval County  
Thursday, July 18, 2024 @ 12:48 PM

Estimated gallons released: 150

Action Taken: Blockage cleared. Area washed down and a load taken off storm drain for full recovery.

Preliminary Cause: Blockage

4008 Arbor Lake Dr W  
Jacksonville, FL 32225  
Duval County  
Sunday, July 28, 2024 @ 11:00 PM

Estimated gallons released: 200

Action Taken: Large vacuum truck cleared the line and roadway washed down.

Preliminary Cause: Blockage

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

None

#### Other Events Reported To The State Watch Office

5609 Buffalo Ave - 7/8/2024 @ 7:23 PM - Non-pcb oil released into storm drain due to heavy rains.

## August 2024

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

6063 New Kings Rd  
Jacksonville, FL 32219  
Duval County  
Sunday, August 4 2024 @ 11:45 AM  
Estimated gallons released: 8100  
Action Taken: Repaired ARV.  
Preliminary Cause: Third Party

1238 Cahoon Rd S  
Jacksonville, FL 32221  
Duval County  
Tuesday, August 6 2024 @ 6:35 PM  
Estimated gallons released:35779  
Action Taken: Pipe replaced and repaired. Street washed down. Sampling began 8/7/2024.  
Preliminary Cause: Pipe Failure

11647 Gwynford Ln  
Jacksonville, FL 32223  
Duval County  
Thursday, August 8 2024 @ 11:45 AM  
Estimated gallons released: 250  
Action Taken: Blockage removed. Drive thru line washed down. Sampling began 8/9/2024.  
Preliminary Cause: Blockage

74700 Mills Preserve Cir  
Yulee, FL 32097  
Nassau County  
Friday, August 9 2024 @ 7:49 PM  
Estimated gallons released: 9000  
Action Taken: ARV shut off. Washed down manhole and ditch. Vacuumed sewer.  
Preliminary Cause: Failed ARV

Bagpipe Ln & Macdougall Dr  
Jacksonville, FL 32244  
Duval County

Friday, August 23 2024 @ 3:25 AM

Estimated gallons released: 3100

Action Taken: Valves shut off. Curbs, driveways, roads washed down. Hydrated lime spread. Sampling began 8/24/24.

Preliminary Cause: Unknown

3023 Merlin Dr N

Jacksonville, FL 32257

Duval County

Friday, August 23, 2024 @ 7:36 AM

Estimated gallons released: 1500

Action Taken: A bypass pump was set up to stop overflow. Affected areas washed down and recovered.

Preliminary Cause: Cave-in

11855 Camden Rd

Jacksonville, FL 32218

Duval County

Saturday, August 24, 2024 @ 4:32 AM

Estimated gallons released: 2000

Action Taken: Station wet well pumped down. Sewer vacuumed.

Preliminary Cause: Rainwater intrusion

Zoo Parkway and Imeson Park Blvd

Jacksonville, FL 32218

Duval County

Saturday, August 24, 2024 @ 8:00 AM

Estimated gallons released: 12000

Action Taken: Broken pipe repaired. Parking lot washed down and loads taken from impacted pond.

Preliminary Cause: Cave-in

804 McDuff Ave N

Jacksonville, FL 32254

Duval County

Monday, August 26, 2024 @ 11:31 AM

Estimated gallons released: 100

Action Taken: Blockage removed to stop overflow from cleanout. Lime will be placed on affected area in rear of property.

Preliminary Cause: Grease

9500 Baymeadows Rd

Jacksonville, FL 32256

Duval County

Monday, August 26 2024 @ 7:05 PM

Estimated gallons released: 9750

Action Taken: Blockage was cleared and overflow was stopped. Pavement over man hole was removed. Affected area was washed down and remaining wash water and sewer was recovered.

Preliminary Cause: Blockage

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

4280 Bleinheim Pl

Jacksonville, FL 32225

Duval County

Thursday, August 1 2024 @ 7:00 PM

Estimated gallons released: 400

Action Taken: Blockage removed. Road and curb washed down and vacuumed.

Preliminary Cause: Blockage

756 Eagle Point Dr

St. Augustine, FL 32092

St. Johns County

Tuesday, August 6 2024 @ 10:00 PM

Estimated gallons released: 600

Action Taken: Remove blockage. Washed down street and recover with vacuum truck.

Preliminary Cause: Blockage

2344 Edgewood Ave W

Jacksonville, FL 32209

Duval County

Thursday, August 15, 2024 @ 11:20 AM

Estimated gallons released: 500

Action Taken: Pipe replaced over ditch to stop sewage release. Investigative sampling on creek determined no waterway impact.

Preliminary Cause: Cave-in

9052 New Kings Rd

Jacksonville, FL 32219

Duval County

Friday, August 30, 2024 @ 10:48 AM

Estimated gallons released: 300

Action Taken: Large vacuum truck recovered standing sewer and washed area down.

Preliminary Cause: Failed ARV

### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

None

### Other Events Reported To The State Watch Office

None

### **September 2024**

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

10148 Deercreek Club Rd E

Jacksonville, FL 32256

Duval County

Wednesday, September 4, 2024 @ 6:30 AM

Estimated gallons released: 1000

Action Taken: Removed blockage. Vacuum truck recovered sewer from storm drain. Street and curb washed down. Sampling began 9/5/24.

Preliminary Cause: Blockage

5643 Pittman Dr N

Jacksonville, FL 32207

Duval County

Wednesday, September 4, 2024 @ 7:32 AM

Estimated gallons released: 500

Action Taken: None. Sampling began 9/5/24.

Preliminary Cause: Storm Event

1747 Clemson Rd  
Jacksonville, FL 32217  
Duval County  
Wednesday, September 4, 2024 @ 10:27 AM  
Estimated gallons released: 500  
Action Taken: None. Sampling began 9/5/24.  
Preliminary Cause: Storm Event

9000 Southside Blvd  
Jacksonville, FL 32256  
Duval County  
Wednesday, September 4, 2024 @ 1:00 PM  
Estimated gallons released: 400  
Action Taken: Servepro called to cleanup inside school. Area washed down where sewer impacted roadway and one load recovered from storm drain.  
Preliminary Cause: Other

3869 San Jose Blvd  
Jacksonville, FL 32207  
Duval County  
Wednesday, September 4, 2024 @ 2:30 PM  
Estimated gallons released: 500  
Action Taken: Recovered sewer on curb, road, and driveway. Sampling began 9/5/24.  
Preliminary Cause: Storm Event

3604 E Ledbury Dr  
Jacksonville, FL 32210  
Duval County  
Thursday, September 5, 2024 @ 8:50 AM  
Estimated gallons released: 750  
Action Taken: Sewer recovered from manholes. Pipe repaired. Curb and street washed down.  
Sampling begins 9/6/24.  
Preliminary Cause: Cave in

2548 Buckman Street  
Jacksonville, FL 32206  
Duval County  
Thursday, September 5, 2024 @ 10:00 PM  
Estimated gallons released: 10,000  
Action Taken: None  
Preliminary Cause: Storm Event

1598 W 16th St.  
Jacksonville, FL 32209  
Duval County  
Thursday, September 5, 2024 @ 10:26 PM  
Estimated gallons released: 500  
Action Taken: None  
Preliminary Cause: Storm Event

4624 Woolman Ave  
Jacksonville, FL 32205  
Duval County  
Friday, September 6, 2024 @ 12:16 AM  
Estimated gallons released: 2,000  
Action Taken: None  
Preliminary Cause: Storm Event

11855 Camden Rd  
Jacksonville, FL 32218  
Duval County  
Friday, September 6, 2024 @ 3:31 AM  
Estimated gallons released: 2,500  
Action Taken: None  
Preliminary Cause: Storm Event

6600 Moret Dr S  
Jacksonville, FL 32244  
Duval County  
Friday, September 6, 2024 @ 7:15 PM  
Estimated gallons released: 3,000  
Action Taken: Pipe repaired. Recovered sewer at lift station and backyard. Hydrated lime spread in grass. No waterways impacted.  
Preliminary Cause: Pipe Failure

13172 Gran Bay Parkway  
Jacksonville, FL 32258  
Duval County  
Saturday, September 7, 2024 @ 12:00 PM  
Estimated gallons released: 1,000  
Action Taken: Removed blockage. Vacuum truck recovered sewer from storm drain. Street and curb washed down. Sampling began 9/8/24.  
Preliminary Cause: Blockage

13172 Gran Bay Parkway

Jacksonville, FL 32258

Duval County

Saturday, September 7, 2024 @ 4:25 PM

Estimated gallons released: 3,000

Action Taken: Removed blockage. Vacuum truck recovered sewer from storm drain. Street and curb washed down. Sampling began 9/8/24.

Preliminary Cause: Blockage

2273 The Woods Dr E

Jacksonville, FL 32246

Duval County

Sunday, September 8, 2024 @ 2:30 PM

Estimated gallons released: 500

Action Taken: None

Preliminary Cause: Storm Event

3632 Valencia Rd

Jacksonville, FL 32205

Duval County

Monday, September 9, 2024 @ 7:07 PM

Estimated gallons released: 300

Action Taken: None

Preliminary Cause: Storm Event

6909 Sonora Dr N

Jacksonville, FL 32244

Duval County

Wednesday, September 11, 2024 @ 9:30 AM

Estimated gallons released: 1000

Action Taken: Vacuum trucks took several loads off system throughout the day until system was able to catch up with flow. No recovery from WOS possible.

Preliminary Cause: Storm Event

2391 Kinwood Ave

Jacksonville, FL 32209

Duval County

Wednesday, September 11, 2024 @ 1:30 PM

Estimated gallons released: 500

Action Taken: Bypass pump set up to stop overflow. New pipe was placed across drainage ditch. No recovery of sewer possible.

Preliminary Cause: Pipe Failure

1641 Firestone Rd  
Jacksonville, FL 32210  
Duval County  
Wednesday, September 11, 2024 @ 9:30 AM  
Estimated gallons released: 12150  
Action Taken: Area was dug up and 2" connection was replaced to stop overflow. No recovery possible due to heavy rains in the area. Fishing creek sampled starting 9/12/24.  
Preliminary Cause: Pipe Failure

2216 Newberry Rd  
Jacksonville, FL 32218  
Duval County  
Thursday, September 12, 2024 @ 7:09 PM  
Estimated gallons released: 1500  
Action Taken: None  
Preliminary Cause: Storm Event

10342 Meadow Point Dr  
Jacksonville, FL 32221  
Duval County  
Thursday, September 12, 2024 @ 7:09 PM  
Estimated gallons released: 3000  
Action Taken: Saddle replaced to stop overflow. Area washed down and vacuum truck recovered loads from impacted storm drain. Sampling of onsite retention pond started 9/13/24.  
Preliminary Cause: Pipe Failure

515 East 9th St  
Jacksonville, FL 32206  
Duval County  
Friday, September 13, 2024 @ 2:13 PM  
Estimated gallons released: 25  
Action Taken: Customer cleaned up sewer inside business. Vacuum trucks have been taking loads off system to assist. Porta potties have been ordered to prevent future overflows until system can be re-laid.  
Preliminary Cause: Pipe Failure

3939 Roosevelt Blvd  
Jacksonville, FL 32205  
Duval County  
Tuesday, September 17, 2024 @ 8:30 AM  
Estimated gallons released: 1000  
Action Taken: Pipe repaired. Vacuum truck pulled loads out of manhole to relieve system. Street washed down. Sampling began 9/18/25.  
Preliminary Cause: Cave in

3442 Victoria Park Rd  
Jacksonville, FL 32216  
Duval County  
Tuesday, September 17, 2024 @ 9:30 PM  
Estimated gallons released: 1500  
Action Taken: Pipe replaced. Street washed down. Sewer recovered from drain. Hydrated lime spread. Sampling began 9/18/24.  
Preliminary Cause: Pipe Failure

7003 San Sabastian Ave  
Jacksonville, FL 32217  
Duval County  
Thursday, September 19, 2024 @ 4:30 PM  
Estimated gallons released: 3500  
Action Taken: Valve installed and removed open ends on the line. Sewer recovered from work pit. Street washed down. Hydrated lime spread. Sampling begins 9/21/24.  
Preliminary Cause: Pipe Failure

3023 Merlin Dr N  
Jacksonville, FL 32257  
Duval County  
Friday, September 20, 2024 @ 12:00 PM  
Estimated gallons released: 650  
Action Taken: Bypass pump repaired. Vacuum truck recovered sewer from work pit. Street washed down. Sampling begins 9/21/24.  
Preliminary Cause: Equipment Failure

5026 Long Bow Rd  
Jacksonville, FL 32210  
Duval County  
Saturday, September 21, 2024 @ 6:42 PM  
Estimated gallons released: 500  
Action Taken: Blockage removed. Street washed down. Sampling begins 9/22/24.  
Preliminary Cause: Blockage

488 Blagdon Ct  
Jacksonville, FL 32225  
Duval County  
Monday, September 23, 2024 @ 1:30 PM  
Estimated gallons released: 500  
Action Taken: ARV repaired, area washed down. Hydrated lime applied to affected area. Sampling begins 9/24/24.  
Preliminary Cause: Third Party

5572 Oak Crossing Dr  
Jacksonville, FL 32244  
Duval County  
September 29, 2024 @ 9:45 PM  
Estimated gallons released: 1500  
Action Taken: Blockage cleared and impacted area washed down. Sampling to begin 9/29/24.  
Preliminary Cause: Blockage

13050 Gran Bay Pkwy  
Jacksonville, FL 32258  
Duval County  
September 30, 2024 @ 10:49 PM  
Estimated gallons released: 500  
Action Taken: Blockage cleared and impacted area washed down. Sampling to begin 9/30/24.  
Preliminary Cause: Blockage

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection -  
Northeast District, COJ-Environmental Quality Division)  
All releases between 50-999 gallons are reported to local agencies.

1840 Cedar Bay Rd  
Jacksonville, FL 32218  
Duval County  
Thursday, September 5, 2024 @ 11:00 PM  
Estimated gallons released: 600  
Action Taken: None  
Preliminary Cause: Equipment Failure

1419 Belvedere Ave  
Jacksonville, FL 32205  
Duval County  
Monday, September 9, 2024 @ 8:32 PM  
Estimated gallons released: 200  
Action Taken: None  
Preliminary Cause: Storm Event

11855 Camden Rd  
Jacksonville, FL 32218  
Duval County  
Thursday, September 12, 2024 @ 11:45 AM  
Estimated gallons released: 800  
Action Taken: None  
Preliminary Cause: Other

2576 Benjamin Rd  
Jacksonville, FL 32223  
Duval County  
Friday, September 13, 2024 @ 10:29 AM  
Estimated gallons released: 300  
Action Taken: Pump repaired and vacuumed sewer back into pod. Area washed down.  
Preliminary Cause: Equipment Failure

375 Popo Pt  
Saint Johns, FL 32259  
St Johns County  
Tuesday, September 24, 2024 @ 10:58 PM  
Estimated gallons released: 800  
Action Taken: Repaired valve. Washed down, vacuumed and applied hydrated lime to impacted area.  
Preliminary Cause: Equipment Failure

57 Spanish Creek Dr  
Ponte Vedra Beach, FL  
St. Johns County  
Wednesday, September 25, 2024 @ 5:45 PM  
Estimated gallons released: 300  
Action Taken: Sewer recovered from storm drain. Street washed down.  
Preliminary Cause: Failed ARV

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

2304 Dean Rd - 9/4/2024 @ 12:15pm - 10 gallons  
5219 Carder St - 9/11/2024 @ 11:28am - 10 gallons

## Other Events Reported To The State Watch Office

218 Autumn Tide Trail  
Ponte Vedra Beach, FL 32081  
St. Johns County  
Thursday, September 5, 2024 @ 1:46 PM  
Estimated gallons released: 250 Reclaim  
Action Taken: Line repaired.  
Preliminary Cause: Third party

10168 Fulcrum Ave  
Jacksonville, FL 32256  
Duval County  
Thursday, September 26, 2024 @ 10:00 AM  
Estimated gallons released: 50 Reclaim  
Action Taken: Line repaired.  
Preliminary Cause: Broken

410 Buckhead Ct  
Saint Johns, FL 32259  
St. Johns County  
Friday, September 27, 2024 @ 8:00 AM  
Estimated gallons released: 2000 Reclaim  
Action Taken: Line shut off.  
Preliminary Cause: Equipment Failure

96362 Piedmont Dr  
Fernandina Beach, FL 32034  
Nassau County  
Friday, September 27, 2024 @ 4:30 AM  
Estimated gallons released: 1259  
Action Taken: Valve closed  
Preliminary Cause: Storm Event

## October 2024

### SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

- **N University Club Blvd and Briar Forest Rd W  
Jacksonville, FL 32277**  
Saturday, October 5, 2024 @ 1:38 PM  
Estimated gallons released: 8000  
Action Taken: ARV replaced. Sewer recovered. Sampling began 10/6/24.  
Preliminary Cause: Failed ARV
- **450 Park St  
Jacksonville, FL 32204**  
Monday, October 7, 2024 @ 7:30 AM  
Estimated gallons released: 200  
Action Taken: Blockage removed. Street washed down.  
Preliminary Cause: Blockage
- **10969 Chitwood Dr  
Jacksonville, FL 32218**  
Thursday, October 17, 2024 5:50 PM  
Estimated gallons released: 5000  
Action Taken: Pipe repaired. Street washed down. Sod replaced. Sampling began 10/18/24.  
Preliminary Cause: Pipe Failure
- **14193 Philips Hwy  
Jacksonville, FL 32256**  
Monday, October 21, 2024 5:00 PM  
Estimated gallons released: 6000  
Action Taken: Pipe repaired. Impacted area washed down. Sewer vacuumed. Hydrated lime spread. Sampling began 10/22/24.  
Preliminary Cause: Pipe Failure
- **Amelia National Pkwy and Amelia Concourse  
Fernandina Beach, FL 32034**  
Wednesday, October 23, 2024 7:41 AM  
Estimated gallons released: 12000  
Action Taken: Pipe repaired. Recovered sewer from excavation pit.  
Preliminary Cause: Contractor Error
- **7897 Blanding Blvd  
Jacksonville, FL 32244**  
Wednesday, October 23, 2024 @ 1:30 PM  
Estimated gallons released: 150  
Action Taken: Debris removed. Sampling begins 10/24/24.  
Preliminary Cause: Blockage
- **Royal County Dr and Panther Creek Pkwy  
Jacksonville, FL 32221**  
Saturday, October 26, 2024 @ 7:20 PM  
Estimated gallons released: 5000

Action Taken: Washed down roadway. Hydrated lime spread.  
Preliminary Cause: Pipe Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

**All releases between 50-999 gallons are reported to local agencies.**

- **1781 Greenridge Cir E  
Jacksonville, FL 32259**  
Thursday, October 3, 2024 @ 10:00 PM  
Estimated gallons released: 100  
Action Taken: Pump was repaired. Customer did not want hydrated lime in yard.  
Preliminary Cause: Equipment Failure
- **1355 Collen Rd  
Jacksonville, FL 32218**  
Thursday, October 10, 2024 @ 9:00 PM  
Estimated gallons released: 600  
Action Taken: Pipe repaired. Road cleaned.  
Preliminary Cause: Pipe Failure
- **3344 Ashridge Dr  
Jacksonville, FL 32225**  
Monday, October 14, 2024 @ 7:00 PM  
Estimated gallons released: 100  
Action Taken: Blockage removed. Sewer recovered and street washed down.  
Preliminary Cause: Blockage
- **2342 Pine Island Ct  
Jacksonville, FL 32224**  
Tuesday, October 22, 2024 @ 9:56 PM  
Estimated gallons released: 50  
Action Taken: Step pump repaired. Hydrated lime spread.  
Preliminary Cause: Equipment Failure
- **11516 Montego Bay Dr W  
Jacksonville, FL 32218**  
Sunday, October 27, 2024 @ 7:05 PM  
Estimated gallons released: 200  
Action Taken: Repaired pipe and cleared blockage. Sewer recovered and roadway washed down.  
Preliminary Cause: Cave-in
- **1309 Edgewood Ave W  
Jacksonville, FL 32208**  
Monday, October 28, 2024 @ 10:37 AM  
Estimated gallons released: 50  
Action Taken: Cleared blockage and stopped overflow. Washed area down and recovered.

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

- 5642 J Ray Cir S - 10/8/24 8:30 AM - 30 gallons
- 1722 Heatherwood Dr - 10/8/24 5:30 PM - 2 gallons
- 3218 Keniston Ln - 10/9/24 10:10 AM - 10 gallons
- 1170 Linwood Loop - 10/16/24 7:00 AM - 10 gallons
- 2505 White Horse Rd W - 10/27/24 - 30 gallons
- 11956 Greenwood Ct - 10/31/24 - 25 gallons

### Other Events Reported To The State Watch Office

- None

### November 2024

#### SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

#### 531 A1A N

##### Ponte Vedra Beach, FL 32082

Thursday, November 7, 2024 @ 12:00 PM

Estimated gallons released: 1000

Action Taken: Recovered in swale. Hydrated lime spread.

Preliminary Cause: Equipment Failure

#### 9735 Sharing Cross Ct

##### Jacksonville, FL 32257

Tuesday, November 12, 2024 @ 9:57 AM

Estimated gallons released: 500

Action Taken: Line jetted to unblock debris in line. Sewer recovered from storm drain. Road washed down. Sampling began 11/13/24.

Preliminary Cause: Third Party

#### 245 Crosswater Lake Dr

##### Ponte Vedra Beach, FL 32081

Wednesday, November 13, 2024 @ 8:47 PM

Estimated gallons released: 2500

Action Taken: Road washed down. Recover sewer from storm drain. Hydrated lime spread.

Preliminary Cause: Failed ARV

12084 Flynn Road

**Jacksonville, FL 32223**

**Wednesday, November 19, 2024 @ 6:38 AM**

Estimated gallons released: 20,000

Action Taken: Pipe repaired. Affected area washed down and recovered standing sewer, ditch water, and wash water. Hydrated lime applied to ditch. Sampling of Mill Creek to begin 11/20/24.

Preliminary Cause: Pipe failure

**5520 Cleveland Rd**

**Jacksonville, FL 32209**

**Sunday, November 24, 2024 @ 10:00 AM**

Estimated gallons released: 1000

Action Taken: Washed down road. Vacuumed sewer. Applied hydrated lime to impacted areas.

Preliminary Cause: Blockage

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

**11888 Fitchwood Cir**

**Jacksonville, FL 32258**

**Tuesday, November 5, 2024 @ 2:05 PM**

Estimated gallons released: 500

Action Taken: Sewer recovered from drains. Street washed down. Sampling began 11/6/24.

Preliminary Cause: Blockage

**1527 Palm Ave**

**Jacksonville, FL 32207**

**Wednesday, November 6, 2024 @ 4:00 PM**

Estimated gallons released: 100

Action Taken: Recovered sewer in catch basin. Road and basin washed down.

Preliminary Cause: Contractor Error

**7099 Collins Rd**

**Jacksonville, FL 32244**

**Wednesday, November 6, 2024 @ 10:00 PM**

Estimated gallons released: 50

Action Taken: Road washed down. Sewer recovered.

Preliminary Cause: Failed ARV

**2064 Ernest St****Jacksonville, FL 32204**

Tuesday, November 12, 2024 @ 3:38 PM

Estimated gallons released: 50

Action Taken: Road and storm water basin washed down and vacuumed up.

Preliminary Cause: Blockage

**2139 St Johns Ave****Jacksonville, FL 32204**

Sunday, November 17, 2024 @ 9:15 AM

Estimated gallons released: 200

Action Taken: Pipe repaired. Recovered sewer.

Preliminary Cause: Equipment Failure

**2518 Caney Wood Ct S****Jacksonville, FL 32218**

Monday, November 18, 2024 @ 8:30 AM

Estimated gallons released: 900

Action Taken: Valve repaired. Area washed down and recovered wash water and standing sewer.

Preliminary Cause: Equipment Failure

**500 Ocean St****Jacksonville, FL 32202**

Monday, November 18, 2024 @ 11:00 AM

Estimated gallons released: 100

Action Taken: Blockage removed, and street washed down. Recovered from surcharged storm drain.

**1531 Ryar Rd****Jacksonville, FL 32216**

Wednesday, November 27, 2024 @ 8:43 AM

Estimated gallons released: 50

Action Taken: Area washed down. Recovered sewer by small vacuum truck.

Preliminary Cause: Equipment Failure

**Minor SSO Events**

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

9743 Sharing Cross Ct - 11/9/24 3:00 PM - 20 gallons

11001 Old St Augustine Rd – 11/21/24 4:36 PM – 10 gallons