

January 2025

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

4548 Craven Rd W
Jacksonville, FL 32257
Monday, January 6, 2025 @ 11:30 AM
Estimated gallons released: 10000
Action Taken: ARV shut off and replaced. Sewer recovered out of ditches and storm water channel. Hydrated lime placed on impacted areas.
Preliminary Cause: Third Party

1045 Riverside Ave
Jacksonville, FL 32204
Tuesday, January 7, 2025 @ 1:30 PM
Estimated gallons released: 50
Action Taken: Blockage removed. Scheduled sewer maintenance.
Preliminary Cause: Blockage

653 Monument Rd
Jacksonville, FL 32225
Wednesday, January 15, 2025 @ 9:30 PM
Estimated gallons released: 1000
Action Taken: Washed down road. Recovered sewer from storm drain. Sampling began 1/16/25.
Preliminary Cause: Blockage

4044 Fincannon Rd
Jacksonville, FL 32277
Sunday, January 19, 2025 @ 3:30 PM
Estimated gallons released: 300
Action Taken: Blockage removed. Sampling began 1/20/25.
Preliminary Cause: Cave In

5510 Palmetto Inlet E
Jacksonville, FL 32277
Sunday, January 19, 2025 @ 5:42 PM
Estimated gallons released: 1000
Action Taken: Blockage removed. Washed down road. Recovered sewer from tributary.
Sampling began 1/20/25.
Preliminary Cause: Blockage

4078 Clearbrook Cove Rd
Jacksonville, FL 32218
Sunday, January 19, 2025 @ 6:50 PM
Estimated gallons released: 5000

Action Taken: Blockage removed. Washed down roads. Recovered sewer from storm drains.
Sampling began 1/20/25.
Preliminary Cause: Blockage

469 Trout River Rd
Jacksonville, FL 32208
Sunday, January 6, 2025 @ 9:06 AM
Estimated gallons released: 750
Action Taken: Calloway onsite upon arrival and had one pump running. Large vacuums took loads off system to help stop release. Roadways washed down. No recovery possible due to location/proximity to river.
Preliminary Cause: Equipment Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)
All releases between 50-999 gallons are reported to local agencies.

4700 Margate Dr
Jacksonville, FL 32207
Tuesday, January 7, 2025 @ 1:53 PM
Estimated gallons released: 150
Action Taken: Washed down driveway and recovered sewer from ditch.
Preliminary Cause: Blockage

2055 Hyde Park Rd
Jacksonville, FL 32210
Thursday, January 9, 2025 @ 1:00 PM
Estimated gallons released: 100
Action Taken: Roadway washed down and recovered. Pipe repaired.
Preliminary Cause: Pipe Failure Force Main

6961 Lenoir Ave
Jacksonville, FL 32216
Tuesday, January 14, 2025 @ 1:00 PM
Estimated gallons released: 300
Action Taken: Washed down street and recovered from storm drain. Sampling began 1/15/25.
Preliminary Cause: Blockage

3787 University Club Blvd
Jacksonville, FL 32207
Wednesday, January 29, 2025 @ 9:23 AM
Estimated gallons released: 500
Action Taken: Blockage removed and area washed down. All water/wastewater recovered.
Preliminary Cause: Blockage

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

None

Other Events Reported To The State Watch Office

None

February 2025

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

Pepsi Place and Bowden Rd
Jacksonville, FL 32216
Tuesday, February 4, 2025 @ 7:45 AM
Estimated gallons released: 1700
Action Taken: Recovered sewer from pipe. Washed down curb. Sampling began 2/5/25.
Preliminary Cause: Pipe Failure

6550 Trade Center Dr
Jacksonville, FL 32254
Friday, February 14, 2025 @ 1:30 PM
Estimated gallons released: 12100
Action Taken: Pipe replaced. Sewer recovered from storm drain, excavation pit, and in grass.
Hydrated lime spread. Investigative sampling taken on 2/15/25.
Preliminary Cause: Third Party

12397 San Jose Blvd
Jacksonville, FL 32233
Thursday, February 20, 2025 @ 8:50 AM
Estimated gallons released: 500
Action Taken: Blockage removed, overflow stopped. Area washed down. Sampling of Cormorant Creek 2/21/25.
Primary Cause: Blockage

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

10777 103rd St
Jacksonville, FL 32210
Monday, February 3, 2025 @ 4:28 PM

Estimated gallons released: 100

Action Taken: Crew needed to repair valve to stop overflow. Area washed down and all wash water recovered.

Preliminary Cause: Failed ARV

11820 Central Pkwy

Jacksonville, FL 32224

Wednesday, February 5, 2025 @ 11:30 AM

Estimated gallons released: 400

Action Taken: Washed down street.

Preliminary Cause: Blockage

6750 Ramona Blvd

Jacksonville, FL 32205

Saturday, February 8, 2025 @ 1:59 PM

Estimated gallons released: 600

Action Taken: Blockage stopped. Area washed down and all sewer recovered from ditch. Lime applied to area.

Preliminary Cause: Blockage

5579 Rustic Thorn Rd

Jacksonville, FL 32219

Monday, February 17, 2025 @ 4:28 PM

Estimated gallons released: 50

Action Taken: Blockage removed, area washed down, and one load recovered from storm drain. Full recovery.

Preliminary Cause: Blockage

10683 Northwyck Dr

Jacksonville, FL 32218

Thursday, February 20, 2025 @ 1:36 PM

Estimated gallons released: 100

Action Taken: Blockage removed and area washed down. One load from each storm drain was recovered for a full recovery.

Preliminary Cause: Blockage

1762 Mindanao Dr

Jacksonville, FL 32246

Saturday, February 22, 2025 @ 7:00 PM

Estimated gallons released: 50

Action Taken: Blockage removed from main. Area washed down and load taken from storm drain for full recovery.

Preliminary Cause: Blockage

8449 Grayling Dr S

Jacksonville, FL 32256

Thursday, February 27, 2025 @ 2:31 PM

Estimated gallons released: 50

Action Taken: Blockage cleared, line repaired. Sewer soaked into ground, applied hydrated lime to affected area.

Preliminary Cause: Blockage

910 W 44th St

Jacksonville, FL 32208

Thursday, February 27, 2025 @ 1:49 PM

Estimated gallons released: 50

Action Taken: Blockage cleared. Area washed down and recovered from surcharged storm drain.

Preliminary Cause: Blockage

7557 Tarleton Rd

Jacksonville, FL 32208

Friday, February 28, 2025 @ 4:17 PM

Estimated gallons released: 50

Action Taken: Blockage was cleared. Affected area washed down and recovered.

Preliminary Cause: Grease

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

3920 Jammes Rd

Jacksonville, FL 32210

Wednesday, February 5, 2025 @ 1:28 PM

Estimated gallons released: 5

Action Taken: Crew called in to determine where leak is coming from and repair.

Preliminary Cause: TBD

1471 23rd Cir S

Jacksonville, FL 32206

Tuesday, February 25, 2025 @ 11:19 PM

Estimated gallons released: 20

Action Taken: Blockage was cleared and affected area was washed down and recovered.

Preliminary Cause: Blockage

Other Events Reported To The State Watch Office

12760 Beach Blvd

Jacksonville, FL 32224

Monday, February 24, 2025 @ 8:30 AM

Estimated gallons released: 20000

Action Taken: Repaired reclaim line.

Preliminary Cause: Third Party